Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal,
Sadbhavana Middle School,
Ahagam Shopian.

No: DFES/FP/9/2023-04/CC-7079422-668 Dated 30-01-2026.

Sub: - Fire & Life safety measures/guidelines in favour of Islamic "Sadbhavana Middle School" situated at Ahagam Shopian.

Ref: - Your application submission date, 30-12-2025.

The Inspection of above said school was got carried out by Assistant Director F&E Services command Pulwama vide his office letter no.ADP/F-Prw/2025/57 dated. 12-01-2025 & found that the management has installed 03 units ABC type 06 kg capacity and 01 unit of Co2 type 4.5 kg capacity first aid fire extinguishers in their school premises. Moreover the site is 03 Km away from Fire & Emergency Station Lassipora and is accessible for fire appliance. Since the school is already functioning in four single storeyed structures, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there: -

1. 02 Nos. water type 09 liters fire extinguishers shall be provided in the school building & 01 No. CO_2 type 4.5 kg capacity fire extinguishers shall be provided near electric panel switch board, in addition to already existing fire extinguishers.
2. Wooden components of the structure especially in attic portion shall be given fire retardant treatment of at least two hours rating.
3. Hose Reel shall be installed to entire building connected with the terrace tank of 10,000 Ltrs. Capacity and should be kept at such a place where from every nook and corner of each floor of school building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near terrace water storage tank with dual electric supply for feeding the Hose Reel Hoses.
4. All exits/entrances shall be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the building shall not be used for any kind of storage.
5. First Aid Fire fighting system installed in the school building shall be checked periodically. Staff and students shall be fully trained in handling/operating of fire fighting system installed in the school building.
6. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.)Any deviation found in this regard, these fire safety measures/guidelines issued will be treated automatically withdrawn/cancelled.
7. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. Class/Halls have a capacity of more than 45 students shall have two exits .Grill fitted in the windows shall be removed. Fire/Evacuation drill shall be conducted regularly. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.
9. At present school is functional in four single storeyed GCI sheet roofed structures over wooden truss. Total 14 class rooms, Staff room, Computer Lab, Science Lab, Sports room, and Lab.As such no addition/alteration shall be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, these fire safety measures/guidelines will be treated automatically withdrawn/cancelled.
10. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, these fire safety measures/guidelines issued shall be treated automatically withdrawn/cancelled.
11. These fire safety measures/guidelines shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued.
12. The fire & life safety measures/guidelines is issued in respect of the institution with validity of six months for adoption of all fire safety measures/guidelines mentioned above.
13. The final fire safety certificate will be issued subject to fulfillment of all the fire safety measures/guidelines in letter and spirit.However, before granting permission/recognition/extension or renewal thereof, the concerned authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-282 of 2018 , issued by Education Department with regard to physical facilities & also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.

30/01/2026

Director,
Fire & Emergency Services, J&K,
Jammu/Srinagar

Principal
Sadbhavana Middle School
Ahagam

Principal
Sadbhavana Middle School
Ahagam, Shopian, Jammu & Kashmir
Contact No.: 7006586882